

FM Approvals 1151 Boston-Providence Tumpike P.O. Box 9102 Norwood, MA 02062 USA T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

## **CERTIFICATE OF COMPLIANCE**

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Ex-TIME 40 and 50. Wall Clock IS / I / 1 / ABCD / T4, Ta = 50 °C

## **Equipment Ratings:**

Intrinsically safe for Class I Division 1, Groups A, B, C, and D T4 Ta = 50°C hazardous (classified) locations

Approved for:

ecom instruments D-97959 Assamstadt, Germany





This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600

1998

Class 3610

1999

Class 3810

1989

Original Project ID: 3015562

FM Approval Granted: November 13, 2002

Subsequent Revision Reports / Date FM Approval Amended

Report Number

Date

Report Number

Date

FM Global Technologies LLC

Nicholas P. Ludlam

Technical Team Manager

November 16,2002

